

Interior Items #5 to #26	Yes	No	N/A	Violation Location
19. Floors throughout the school are clean and free of trash, as well as appear free of slipping, tripping and / or other hazards. Egress through halls and exits are clear and accessible.	✓			
20. Supplies and materials are neatly and appropriately stored: a. Storage racks/shelving over 6 feet in height are properly secured from tipping. b. In general, there is no storage within 24 inches of a ceiling. In buildings with sprinkler systems, storage is at least a minimum of 18 inches below sprinkler head deflectors. c. Storage is organized to allow safe access through space.	✓			
21. Provision shall be made for storage of students' clothing in other than a corridor or exitway. Student lockers are usable; i.e.: doors, handles and locks are operable. 6A:26-8.1 (i7)	✓			
22. Drinking fountains are provided with sufficient water pressure or access to water coolers is readily available. (6A:26-12.4) Potable water shall be available and drinking fountains shall be provided for students in cafeterias, preschool and kindergarten programs in accordance with N.J.A.C. 5:23-7; 6A:26-8.1(v).	✓			
23. Toilet facilities shall meet existing UCC requirements for the E Use Group as determined by the construction official. Toilet facilities shall be available within a reasonable distance not more than one floor away, and shall be equipped with an exterior operable window sash or mechanical exhaust ventilation. 6A:26-8.1 (iv)	✓			
24. Food and nonfood items (i.e.: cleaning products, etc.) in home economics rooms & cafeteria are stored separately.	✓			
25. Non-instructional areas are free of all unapproved construction; e.g.: walls, partitions, doors and stairs.	✓			
26. Furniture and equipment that is in good condition and suitable for the age and size of the students and purposes of instruction shall be provided; NJAC 6A:26-8.1(vii)	✓			
Vocational/Laboratories #27 to #34	Yes	No	N/A	Violation Location
27. Corrosives, toxic and other hazardous substances are stored in proper corrosive storage cabinets and are properly labeled.			✓	
28. Required space is available for the safe operation of machinery.			✓	
29. Mechanical and hydraulic automotive lifts have locking devices to hold them in the extended (open) position.			✓	
30. Floor(s) and aisles in all shops are free of slipping and tripping hazards.			✓	
31. "Eye Hazard Area- Wear Your Eye Protection" signs are posted.			✓	
32. The following additional safety measures are in place if welding operations are on-going:			✓	

Interior Items #5 to #26	Yes	No	N/A	Violation Location
cause injury and/or are properly secured. Interior stair treads do not show evidence of extensive wear and are generally in good repair.				
9. Stage curtains need to indicate flame proof or flame retardant and certificates are on file.	✓			
10. All education spaces shall be equipped with a communication devise/system connected to the main office and capable of emergency communication to local authorities or 9-1-1. 6A:26-8.1 (i6).	✓			
11. Electric outlets and/or wiring appear appropriate, including: a. GFI protection for receptacle(s) within 6 ft of water in accordance with code. b. Electrical extension cords and surge protectors used appropriately, with extension cords <i>only used</i> for temporary need(s). c. Sufficient electrical duplex outlets shall be provided to satisfy the program needs as provided in N.J.A.C. 6A:26-6.3 6A:26-8.1(vii2).	✓			
12. Nurse's Office: District boards of education shall provide the necessary facilities, equipment and supplies for the performance of the duties required under State law and the rules by health services personnel. (6A:26-12.3 & 6A:26-6.3(b))	✓			
13. Individual or central mechanical ventilation unit(s) are operating in all student and staff occupied rooms/areas and toilet facilities; air conditioners are operational in windowless interior areas. Heating and ventilation requirements shall be as set forth in N.J.A.C. 6A:26-6.3 and the UCC. 6A:26-8.1 (iii).	✓			
14. Lighting levels in all instructional areas at least 50 foot candles, as measured with a light meter, comply with code and lamps/bulbs are covered with a lens cover or equivalent protection. (6A:26-8.1(vi) & 6A:6.3(g)(1))	✓			
15. Instructional areas have no unauthorized and/or potentially hazardous materials/equipment in rooms. 6A:26-8.1 (i1)	✓			
16. A chalkboard or whiteboard, and/or display board is provided in each instructional space and is free of cracks and jagged edges. 6A:26-8.1 (vii1)	✓			
17. Ceilings, walls and floors are free of holes, sags, and evidence of water damage. The average ceiling height shall be at least 8' feet for instructional spaces in temporary facilities in an existing public school, in a district owned facility and in rented or leased buildings not on school district owned sites. 6A:26-8.1 (ii)	✓			
18. Area and floor drains, where provided, appear to be in working order and covered with appropriate plates; unused (abandoned) waste lines (drains) are sealed off and capped.	✓			